

May 22, 2020

Kipabiskau Regional Park  
Box 325  
Tisdale, SK  
S0E 1T0

**RE: Rescinding - Precautionary Drinking Water Advisory – Kipabiskau Regional Park**

The Water Security Agency, in consultation with the Saskatchewan Health Authority, are advising that the **“Precautionary Drinking Water Advisory”**(PDWA) issued by the Water Security Agency for Kipabiskau Regional Park’s potable water system be rescinded, as of 1:00 pm Friday May 22, 2020.


The rescinding of the PDWA was based upon information provided by your system, which included:

- The system has been flushed;
- The turbidity in the system is within regulatory requirements;
- Chlorine residuals throughout the WTP and distribution system are within regulatory requirements;
- and
- Bacteriological sampling is within regulatory limits.

In closing, I would like to acknowledge that the Water Security Agency appreciates the efforts and cooperation demonstrated by staff at your water treatment plant, as well as officials of the Park in addressing the advisory.

Should you have any questions or concerns, please call me at (306) 862-1767.

Sincerely,



Ries Mansuy, A.Sc.T.  
Sr. Environmental Project Officer  
Water Security Agency – Environmental and Municipal Management Services Division  
Nipawin, SK.

CC. Barry Wright, Environmental and Municipal Management Services Division  
Saskatchewan Health Authority-Kelsey Trail Region  
Environmental and Municipal Management Services Division, Regina